



\*J1-BAT (APS) : Set this jumper according to battery number. Connect charge voltage to transformer. For 4 battery = 48V, For 5 battery = 55V.

TRANSFORMER / 250W

SAFETY LINE

FUJI FRENIC LIFT INVERTER

ACT

INPUTS & SIGNAL ACPK

This document is a sample for applications. All information contained in these materials are subject to change by SKY ELEVATOR without notice. SKY ELEVATOR assumes no responsibility for any damage, liability, or other loss rising from these inaccuracies or errors.

ACT FUJI LIFT INVERTER AND RESCUE SYSTEM WITH UPS

SKY ELEVATOR	PROJ.	SKY 911 (ACT)	DRW.	SKY
	REV.	00	DATE	11 APR 2013

F/7.5.5.02.69  
71-A03 : LIFT TYPE/006(VVVF1)